



Office:- Sub Divisional Engineer, Water Supply & Sanitation Sub Divison,
Khuian Sarwar
email- sde.wsskhuiansarwar@gmail.com

No.377

Date:-11-05-2023

To

The Principal,
Shri Guru Jambheshwar DAV Sr. Sec. Public School,
VPO Haripura, Near Panjkosi Railway Station
Fazilka, Abohar, Ferozpur, Punjab-152128

Subject:- Regarding issuing a certificate of Sanitary Conditions and
Drinking Water.

Ref:- Your office letter no. DAV/695/22-23 dated 17.01.2023

In the above cited subject under your reference it is stated that as per water testing sample report, the provision of Toilets and drinking water provision of 1200 LPH RO System is sufficient. So it certified that Sanitary Conditions and Drinking Water arrangement in your school is satisfactory.

Sub Divisional Engineer,
Water Supply & Sanitation Sub Divison,
Khuian Sarwar.

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਵ/ਸ ਅਤੇ ਸਿਟੀਟੈਲਰ
ਉਪ ਮੰਡਲ ਖੁਦੀਆਂ ਸਕਲਾ:

Principal
S.G.J. DAV Sr. Sec.
Pub. School, Haripura

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

TEST REPORT


Name & Address of Customer Principal, S.G.J D.A.V Sr. Sec. Public School V.P.O Haripura, Tehsil Abohar, District Fazilka	Customer Reference No. No : Dated : 20/03/2023 Sample Submitted by Principal Date of Sample Receipt 20/03/2023 Analysis Starting Date 20/03/2023 Analysis completion Date 20/03/2023
--	---

Discipline : Chemical Testing IIR No. : TC000123000000122F Test Report No. : Abohar/2223/00336 Registration no. : Abohar/REG2223/00361 Source : CANAL Scheme : Hari Pura Village : Hari Pura Block : Khuian Sarwar Latitude : Not Mentioned	Group : Water Sample Type : Water Date of Issue : 20/03/2023 Condition of Sample : Sealed Quantity/Type of Bottle : 1000 ml / Plastic Bottles Location/Depth : S.G.J D.A.V Sr. Sec. School, Haripura / NA Habitation : Hari Pura District : Fazilka Longitude : Not Mentioned
--	--


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.30	6.5-8.5	No Relaxation		IS 3025 (Part 11: 1991) Electrode Method
2	Colour	1	5	15	CU	IS 3025 (Part 4: 2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable		IS 3025 (Part 5: 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable		IS 3025 (Part 8: 1984) (RA 2017)
5	TDS	290	500	1000	mg/l	IS 3025 (Part 16: 1984) Gravimetric Method
6	Turbidity	1	1	5	NTU	IS 3025 (Part 10: 1984) Nephelometric Method
7	Alkalinity	88	200	600	mg/l	IS 3025 (Part 23: 1986) Indicator Method
8	Hardness	96	200	600	mg/l	IS 3025 (Part 21: 2019) EDTA Method
9	Calcium	30	75	200	mg/l	IS 3025 (Part 40: 1991) EDTA Titrimetric Method
10	Magnesium	5	30	100	mg/l	APHA (21st Ed 2017) Method: 3500-Mg-2 B. By Calculation Method
11	Chloride	48	250	1000	mg/l	IS 3025 (Part 32: 1988) Argentometric Method

This Report is issued under the following terms & Condition

1. The results apply to the sample as received only
2. The sample will be destroyed after retention time unless otherwise specified specially
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law
4. Abbreviation used: TDS = Total Dissolved Solids; mg/l = milligram per liter; BOD = Bio-oxidation limit; APHA = American Public Health Association; Indian Standard; NT = Not Tested; NA = Not Applicable; NTU = Nephelometric Turbidity Unit; RA = Reaffirmed; ND = Not Detected
5. * Value not available or test not performed for this parameter


 Mrs. Manju
 Quality Manager
 Authorized Signatory
 For, Block Water Testing Laboratory, Abohar

----- End of the Test Report -----


 Principal
 S.G.J. DAV Sr. Sec.
 Pub. School, Haripura